

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
 District Disaster Response & Fire Officer
 Andhra Pradesh, Palnadu

To:
 District Educational Officer, Palnadu
 District, Narasaraopet,

File No: 34980/PLN/DEO/2026, Date:25/09/2026
Occupancy NOC RC Number: 4082/2011

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Needy Illiterate Children Education (NICE)**, represented by **P Purna Chandra Rao, Mynampadu Village, Nadendla Mandal, Palnadu District, A.P., Pincode:522549.** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.01-09-2025.
 3. This Office NOC for Occupancy Rc No. 4082/2011, Dt.21/09/2011
 4. Renewal NOC For Occupancy 4082/2011, Dt.16/09/2025
 5. Online Application for Renewal NOC of P Purna Chandra Rao, Mynampadu Village, Nadendla Mandal, Palnadu District, A.P., Pincode:522549. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 23-09-2026.

-- x --

The Management of Needy Illiterate Children Education (NICE), represented by P Purna Chandra Rao, Mynampadu Village, Nadendla Mandal, Palnadu District, A.P., Pincode:522549. has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.19713/- vide challan No. 10113173612026, Dated 22/09/2026 at ONLINE, ONLINE.

Needy Illiterate Children Education (NICE)

2. The builder has constructed a Non Multi Storeyed Building with Ground Floor + One Upper Floor with a height of 6.2 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 455.00 sq. meters.
3. Open Spaces:

NOTE: It is the responsibility of the local Municipal authorities i.e., Municipal Corporations, Panchayats, IALA, SEZ, APIIC etc., to ensure the setbacks as per local building rules are in force vide G.O.Ms.No.44 Home (Prisons & Fire) Department Dated:12-03-2024.

4. The builder has provided the following means of escape:

Sl	Details of Staircases	Required Nos / Meters as per NBC	Provided Nos / Meters
1	Internal Staircases	Min 1 No. - 1.5 Meters	2 Nos. - 0.95 Meters Each
	Total	3 Meters	1.90 Meters

5. Occupant Load :

Sl	Floor	Built up area (Sq Mtrs)	Occupancy Type	No of Occupants as declared by the builder	No of Occupants as per NBC	Aggregate width of Staircases Required (Meters)	Aggregate width of Staircases Provided (Meters)
1	Ground Floor	422.54	Educational	100	105	1.00	1.90
2	First Floor	365.98	Educational	90	91	0.90	1.90
	Total	788.52		190			

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

Sl	Fire Fighting Equipment	Provided
1	Fire Extinguishers	8 Nos.
2	Hose Reel Systems	2 Nos.
3	Down Comer	1 Nos (For Each Floor)
4	Terrace Tank	10,000 Ltrs Ltrs
5	Booster Pump	450 LPM

- Provide ABC 5 kg/6 kg fire extinguishers

7. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023

8. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate vide reference 4th cited to the existing Non Multi Storeyed Building.

9. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate P **Purna Chandra Rao Mynampadu Village, Nadendla Mandal, Palnadu District, A.P., Pincode:522549.**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.

4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.
---	---	--	--

10. The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

11. This Periodical Renewal Fire Certificate is valid from 25/09/2026 to 24/09/2031.

12. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire Services Act 1999 and Rules, 2006.

13. Challan Info:

Challan Number	Challan Date	Challan Amount
10113173612026	2026-09-22	19713

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended by the management.

Nil

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షితమైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై సమూహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."

Your Sincerely,



[Signature]
25/9/26
District Disaster Response & Fire Officer,
Palnadu District

In case of emergency, please call 101 or 08647-222101 or 9963732206

Copy to Management P Purna Chandra Rao, Mynampadu Village, Nadendla Mandal, Palnadu District, A.P., Pincode:522549.

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned